



Office No. 9, Aakashganga Society, Near ICICI ATM, Pimple Nilakh, Pune 411027.
Call: +91 9822757322, 020 27271660 | satyamfire11@gmail.com | www.satyamfire.in

FORM – B

Date: 1/1/2023

(See section 3 (3) and rule 4 (2))

Certificate by the Licensed Agency regarding the compliance of the Fire Prevention and Life Safety Measures.

CERTIFICATE

I / We Further certify that these installations in the above mentioned Building are maintained good repair and efficient conditions during the period 1 Jan 2023 – 30 June 2023, as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006(Mah-III of 2007). The details of the inspection and maintenance of installation carried out by me/us are mentioned as below, herewith.

The details of the work and related activities which I or we have executed or performed are mentioned In the list appended herewith.

Location of Site or Premises

Symbiosis

Symbiosis School Nashik, Plot No.53, Sector S.S, C. - S.S.A NH Shravan,
CIDCO, Ashwinnagar, Nashik-422009

Satyam Fire

**S.No.67, House No205, Ganesh Nagar,
Pimple Nilakh,
Pune 411027**

License No. MFS-LA/RF-87

Date: - 1/1/2023

Shahitya
Headmistress
Symbiosis School
Nashik

Netaji
HON'BLE CO-ORDINATOR
SYMBIOSIS, NASHIK.

MAHESH
NETAJI SATHE
Authorized Signatory



Office No. 9, Aakashganga Society, Near ICICI ATM, Pimple Nilakh, Pune 411027.
Call: +91 9822757322, 020 27271660 | satyamfire11@gmail.com | www.satyamfire.in

Date: 1/1/2023

Description of Building or Premises.

Symbiosis

Symbiosis School Nashik, Plot No.53, Sector S.S, C. - S.S.A NH Shraavan,
CIDCO, Ashwinnagar, Nashik-422009

The details of the work and related activities which I or we have executed or performed are mentioned in the list appended herewith.

SR.NO	ITEMS	PARTICULARS	QTY.
1	FIRE PUMP	MAIN FIRE PUMP ELECTRIC DRIVEN (KIRLOSKAR MAKE) JOKEY PUMP DIESEL ENGIN PUMP TERRACE BUSTER PUMP	01 NOS 01 NOS 01 NOS 03 NOS
2	YARD HYDRANT	PROVIDE YARD HYDRANT OR RING HYDRANT AROUND THE BUILDING 150MM/80MM G.I PIPE IS1239.	
3	EXTINGUISHERS	PORTABLE FIRE EXTINGUISHERS IS: 15683/2006 ABC 4KG.	INSTALLE
4	SINGLE HYDRANT VALVE	PROVIDE AT VARIOUS LOCATION 63MM AS PER IS-5290.	INSTALLE
5	HOSE BOX	PROVIDE AT VARIOUS LOCATION.AROUND THE BUILDING.	INSTALLE
6	HOSE PIPE	PROVIDE AT VARIOUS LOCATION AS PER IS-636	INSTALLE
7	BRANCH PIPE	PROVIDE AT VARIOUS LOCATION AS PER IS- 903	INSTALLE
8	HOSE REEL	PROMINENT PLACES.PROVIDE AT STRATEGIC LOCATION. 30 MTR.19MM.IS884:1985	INSTALLE
9	FIRE BRIGADE CONECTION	PROVIDE MAIN GATE	INSTALLE
10	MANUALLY OPERATED FIRE ALARAM SYSTEMS	FACTORY SHED & OFFICE BUILDING.PROVIDE AT VARIOUS LOCATION	INSTALLE

Satyam Fire
S.No.67, House No205, Ganesh Nagar,
Pimple Nilakh,
Pune 411027
License No. MFS-LA/RF-87

Date: - 1/1/2023

Mahesh Netaji Sathe
Symbiosis School
Nashik

HON'BLE REPRESENTATIVE
SYMBIOSIS, NASHIK.

MAHESH
NETAJI SATHE
Authorized Signatory